



JAMES J. BLANCHARD, Governor

DEPARTMENT OF PUBLIC HEALTH

3500 N. LOGAN
P.O. BOX 30035, LANSING, MICHIGAN 48909
GLORIA R. SMITH, Ph.D., M.P.H., F.A.A.N., Director

August 22, 1988

Mr. Dick Beard
Hi-Mill Manufacturing
1704 Highland Road
Highland, Michigan 48031

Dear Mr. Beard:

On July 14, 1988 a representative of the Oakland County Health Division and Michigan Department of Public Health collected water samples from your wells as a part of the groundwater monitoring program. Enclosed please find the laboratory report which lists the parameters tested, test results, standard health maximum contaminant level, if established, and minimum laboratory detection limits.

The results of the partial chemical analysis was satisfactory. The results of the volatile organic analysis revealed 0.004 mg/L benzene in well #1 and 0.001 mg/L trichloroethylene in well #2. The results of the metals analysis revealed 0.15 mg/L barium, 0.006 mg/L arsenic, and 2.0 mg/L iron in well #1 and 0.1 mg/L copper, 0.26 mg/L zinc, 0.007 mg/L lead, 6.5 mg/L iron, 0.19 mg/L barium, and 0.007 mg/L arsenic in well #2.

If you have any questions, feel free to contact Ron Holben at (517) 335-8329 or me at (517) 335-9175.

Sincerely,

A handwritten signature in cursive script, appearing to read "Julie M. Parsons".

Julie M. Parsons, Sanitarian
Ground Water Quality Control Section
Division of Water Supply
Bureau of Environmental and
Occupational Health

JMP:s11



PRINTED ON
RECYCLED PAPER